

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1574:120 Page 1 of 1

CATEGORY: Misc Device/Control Unit Accessories

LISTEE: ADT Security Service, Inc., 695 Route 46 West, Suite 200, Fairfield NJ 07004
Contact: Ron Dalton (310) 725-2972 FAX (310) 725-2942

DESIGN: Optional detector accessories:

SIGA-LED	Remote LED Alarm Indicator
SIGA-DTS	Remote Test Station
SIGA-DG	Smoke Detector Guard
*EC-LED	Remote LED Alarm Indicator

All prefixes may be followed by a alpha character between A and Z except C to classify a specific market.
Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as optional accessories. Intended for use with separately listed compatible detectors. Model SIGA-DG is intended for use only with Models *ADT-IPHS (CSFM Listing No. 7258-1574:109) and *ADT-PS (CSFM Listing No. 7272-1574:110) smoke detectors. Refer to listee's Installation Instruction Manual for details.

XLF: 7300-1591:127

*Rev. 02-13-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **FEBRUARY 13, 2004**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**